

**Utah Division of Water Quality
Salt Lake City, Utah**

**ADDENDUM
Statement of Basis (Wasteload Analysis & TMDL)
Level I Antidegradation Review**

Date: October 12, 2009
Facilities: Perry/Willard Regional WWTP, Perry, UT
Receiving water: Great Salt Lake Mudflat Wetlands [Class 5E]

Finding Insignificant Impact – Negative Declaration

The discharge from the above listed facility was evaluated for impact to its receiving water.

It has been determined that this discharge will not cause a violation of water quality in downstream receiving waters. Water quality standards are met at the discharge to the Refuge. Therefore, a wasteload allocation based upon water quality numeric criteria is not required.

Permit limits should be set according to rules found in R-317-1.

Antidegradation Level I Review

An Anti-degradation Level II review is not required since the water quality of the receiving water will not be degraded by the proposed activity (e.g., a UPDES permit is being renewed and the proposed effluent concentration value and pollutant loading is equal to or less than the existing effluent concentrations value and pollutant loading. [R317-2-3.4.1b.1])

Prepared by:
William O. Moellmer, Ph.D.
Utah Division of Water Quality

